

JAS (Inspection & Testing) Ltd

Summary of Glass Impact Test Report

To BS6206: 1981 for Glass Safety

Test Consultant : **JAS (Inspection & Testing) Ltd.**

Report Ref. : J19-100-R01-190711 (Summary)

Manufacturer : **Guangdong South Bright Glass Technology Co., Ltd.**

Manufacturer Address : 廣東省佛山市高明區富灣工業園

Product Name : Tempered Glass of the thicknesses:
19mm & 22mm

Density : Approx. 2500 kg/m³
(Specimen made into 1930mm x 865mm samples.)

Test Results : Comply to Class A

No. of Specimens Tested : 12 nos. for each thickness

Performance : Glass did not break

Date of Test : 10th July 2019

Certified by



Mr. Clifford A. Bury

